

INVESTIGATION OF MVAR VARIATION IN MADINAH AND MAKKAH SAUDI ELECTRICITY NETWORKS UNDER THE EFFECT OF COMPENSATION

MOHAMMED MUAYTIQ AL HARBI	1411104
GEHAD KHALEL AL HARBI	1409408
ABDULLAH AHMED AL GHAMDI	1320243
KHALED ABDULGADER AL SUBHI	1409308

Submitted in partial fulfillment of the requirements for the degree of
Bachelor of Science

**Department of Electrical Engineering
Faculty of Engineering, Rabigh
King Abdulaziz University**



1438 - 1439 H (2017-2018 G)

ABSTRACT

In the current investigation, the effect of using shunt and series capacitors compensation on power systems operation will be discussed. Shunt and series capacitors are to be applied on networks of Madinah and Makkah. The investigation has been conducted in the following :

Load flow studies are performed for Madinah and Makkah system voltages 380kv, 110 kV and 33KV. Three different load levels (light, medium and peak) have been considered in the investigation. Power World Simulator PWS has been used to perform the load flow analysis. The obtained results of load flow studies are compared to the actual load flow and found identical.

Development of a systematic programming method to find the locations of implementing series capacitors on Madinah and Makkah network. Transmission lines of 380 kV, 110 kV and 33KV have been considered. It was noticed that series capacitor compensation increases the power transmission capability of some major high voltage transmission lines by more than 200%. Development of a systematic programming method to find the locations of implementing shunt capacitors on Madinah and Makkah network. It was found that the use of shunt capacitor compensation reduces the reactive power generation by around 52% during the peak time.

Development of a systematic programming method to find the locations of implementing mixed shunt and series capacitors on Madinah and Makkah network. Both voltage levels 380kV and 110kV have been investigated for each city in Madinah and Makkah. It was found in the investigation that mixed compensation reduces the reactive power generation significantly and increases the transmission capability of the network around 46 % reduction in generated Mvar obtained during peak load when using mixed compensation.



INVESTIGATION OF MVAR VARIATION IN MADINAH AND MAKKAH SAUDI ELECTRICITY NETWORKS UNDER THE EFFECT OF COMPENSATION



Mohammed Muaytiq Alharbi 1411104
Gehad Khalel Alharbi 1409408
Abdullah Ahmed Alghamdi 1320243
Khaled Abdulgader Alsubhi 1409308

Advisor: Dr. Youssef A. Mobarak

Department of Electrical Engineering
Faculty of Engineering – Rabigh
King Abdulaziz University

INTRODUCTION

Load flow studies are performed for Madinah and Makkah Saudi Electricity Network voltages (380, 110, 33)KV. Three different load levels (light, medium and peak) have been considered in the investigation. Power World Simulator PWS has been used to perform the load flow analysis. The obtained results of load flow studies are compared to the actual load flow and founded identical. Shunt capacitors installed in transmission and distribution networks will increase transmission capability, reduce losses and improve the power factor. High voltage banks for any voltage and power rating can be designed by series and parallel connection of capacitor units. Shunt capacitors are primarily used to improve the power factor in the network. Inductive loads consume reactive power, e.g. magnetization power for transformers, motors and reactors. The reactive power needed is generated by capacitors. Real and reactive power can be controlled by else off nominal tap ratio changing and regulating transformer.

PROJECT OBJECTIVES

The main scope of this study is to investigate the effect of Mvar variation in an electrical power system under the effect of compensation. The study will be conducted on part of the Saudi Electricity Company (SEC) power network Madinah and Makkah, which results in minimum reactive power generation while satisfying the system constraints. Therefore, the main objective of this project can be summarized as follows:

- Load flow studies are to be performed on different Madinah and Makkah system levels, i.e. 380 kV and 110 kV.
- These load flow results should be compared with the actual load flow as recorded in the Madinah and Makkah load dispatch centers.
- Find the optimum number, location(s) of shunt capacitors which minimize the objective function while satisfying the system constraints.
- Recommendation which size of capacitors might be needed.
- Off-nominal tap ratio studied for Madinah and Makkah city to control of active and Reactive power flow.

PROJECT FRAMEWORK / METHODOLOGY

The idea of this study the Saudi Electricity work is to company a wide range of capacitor compensation vision and the expected outcome. This analysis should guide the network operators on what and where the capacitor compensation are needed during each load level. In this method, the optimization process consists of four major steps.

- First is the choice of the location. The program scans all the buses and calculate the objective function at each time for single bus shunt compensation.
- Second is the improvement of the solution considering the standard bank size. The aim of this step is to decrease the objective function.
- Third, the program will sort the best ten locations and their objective functions.
- Fourth, The algorithm will stop when there is no further improvement in the objective function from the previous case.

RESULTS AND DISCUSSION

The obtained results of load flow studies are compared to the actual load flow and founded identical. Shunt capacitors installed in transmission and distribution networks will increase transmission capability, reduce losses and improve voltage load.

By power factor correction in group of loads to 0.97, the voltage profile on bus #1060 improved from 0.932 p.u. to 0.95 p.u., and the real power losses reduced from 11.89 MW to 11.34 MW while the reactive power losses reused from 181.5 Mvar to 169.86 Mvar

For the off nominal tap ratio of transformer between 1300-1310 buses, off-nominal tap ratio is 0.96 then P_{loss} is 91.61 MW and Q_{loss} is 357.81 Mvar, the voltage load bus #855 0.827 p.u. by increasing off-nominal tap ratio the real and reactive power losses will decreased




Figure 3 : Load voltage profile

Table 1: Load Flow Result For Madinah Network

Base Case	Light Load	Medium Load	Peak Load
P_g (MW)	805	1156.8	1509.7
Q_g (Mvar)	439	672.2	1013.8
S_g (MVA)	905	1337	1823
P_{loss} (MW)	3.7	8	16.4
Q_{loss} (Mvar)	-44	<0.8	202.8




Figure 4 : Active power losses

Table 2: Load Flow Result For Makkah Network

Base Case	Light Load	Medium Load	Peak Load
P_g (MW)	2012.49	1557.23	1092.25
Q_g (Mvar)	1920.88	1092.25	357.81
S_g (MVA)	1167	1796	2514
P_{loss} (MW)	16.52	44.34	91.61
Q_{loss} (Mvar)	-233.27	0.13	357.81




Figure 5 : Reactive power losses

CONCLUSION AND RECOMMENDATIONS

- Applying shunt compensation as close as possible to loads is more economical than compensating at the 380 kV network.
- Shunt compensation at substations with large loads results in a better reduction of the generated MVA than at substations with low loads.
- The effect of the off-nominal tap ratio was studied for each network based on the maximum reduction in the generated MVAR.

REFERENCES

- [1] Cai L.J., Erlich L and Stamtis, G. "optimal choice and allocation of FACTS devices in deregulated electricity market using genetic", Power Systems conference and exposition, vol. 1, pp. 201-207, 2004.
- [2] Abdullah Alshehri, Ahmad Hussain, and Youssef Mobarak, "Energy-Conversion Measures in the Industries of Saudi Arabia and Development of Methodology For Certification of Energy Personnel in the Kingdom", Elsevier, Energy Policy, Vol. 64, pp. 203-208, 2014.